





**“EXACT FIT”  
Replacement  
Filter Element  
Specification**



<b>PNEUMAFIL PART NUMBER .....</b>	<b>A43459C1</b>	<b>A43460C1</b>
<b>DONALDSON REF. NUMBER .....</b>	<b>P19-1280</b>	<b>P19-1281</b>
<b>Shape .....</b>	<b>Cylindrical</b>	<b>Conical</b>
<b>Effective Filtration Area.....</b>	<b>190 F<sup>2</sup> / 17.7 m<sup>2</sup></b>	<b>230 F<sup>2</sup> / 21.4 m<sup>2</sup></b>
<b>Length of Element without Gasket.....</b>	<b>26” / 660 mm</b>	<b>26” / 660 mm</b>
<b>Outer Diameter .....</b>	<b>12.75” / 324 mm</b>	<b>17.5” x 12.75” / 445 mm x 324 mm</b>
<b>Inner Diameter.....</b>	<b>8.38” / 213 mm</b>	<b>13” x 8.38” / 330 mm x 213 mm</b>
<b>Number of Pleats .....</b>	<b>278</b>	<b>337</b>
<b>Pleat Depth .....</b>	<b>1.9” / 50 mm</b>	<b>1.9” / 50 mm</b>
<b>Media.....</b>	<b>Cellulose/Polyester/Electrostatic Membrane</b>	
<b>Inner &amp; Outer Liners .....</b>	<b>G60 Galvanized Expanded Steel</b>	
<b>Endcaps .....</b>	<b>G60 Galvanized Steel with Media Potted in 2-Part Polyurethane</b>	
<b>Gasket.....</b>	<b>Molded Polyisoprene</b>	
<b>Test Airflow Rate.....</b>	<b>1533. cfm for the pair</b>	
<b>Initial Resistance.....</b>	<b>0.85” w.g. / 21.6 mm w.g.</b>	
<b>Initial Fractional Efficiency Per ASHRAE Test 52.2</b>	<b>Efficiency at 1.16” / 29.5 mm w.g. pressure drop Per ASHRAE Test 52.2</b>	
<u>Particle Size</u> <u>Efficiency</u>	<u>Particle Size</u>	<u>Efficiency</u>
½ micron        91.4%	½ micron	100.0%
1 micron        96.7%	1 micron	100.0%
1 ½ microns    97.8%	1 ½ microns	100.0%
2 microns       98.9%	2 microns	100.0%
2 ½ microns    99.3%	2 ½ microns	100.0%
<b>Average Dust Spot Efficiency Per ASHRAE Test 52.1.....</b>	<b>99.6% / EU9</b>	